Date: 1/7/2026

Milne Grove Elem School,

Thank you for participating in Lockport's Lead & Copper Monitoring Program. We are providing your specific tap water results from the sample collected at 565 E 7th St on 10/20/25.

Your Sample Results:

Lead (ND = Not Detected):

- Drinking Fountain ND ppb
- Drinking Fountain ND ppb
- Kitchen ND ppb
- Nurse's Office ND ppb
- Classroom ND ppb

(This is below the Lead Action Level of 15 ppb)

What This Means:

- While your results are below the action level, lead is a common plumbing material in older buildings. If you are concerned, you can take steps to reduce exposure, such as flushing your tap.

Health Information:

- Health Effects of Lead. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney, or nervous system problems

Steps You Can Take:

What you can do to reduce lead exposure in drinking water:

- *Run your water to flush out lead.*
  - Flushing times can vary based on the length of your lead service line and the plumbing configuration in your home. The length of lead service lines varies considerably.